



east meets west
FOUNDATION

THE FOUNDATION FOR LEARNING, HEALING AND HEALTH IN VIETNAM

WATER TEST REPORT

CrystalPur Filter Test

1. Name of sample: Treated water collected from the ferry of Han River
2. Implementation date: 17th, Feb, 2009
3. Equipment: LaMotte Rapid Testing Kit and the report from Environmental Technology Centre of Danang Department of Natural Resources & Environment
4. Test results:

No	Water Quality Criteria	Units	Reading	Allowable Limits
1	pH	N/a	6,73	6,5-8,5
2	Turbidity	NTU	< 1	< 2
3	TDs	Mg/l	130	1000
4	Hardness	Mg/l	55	300
5	Salinity	Mg/l	89	250
6	Iron(Fe)	Mg/l	0,10	0,5
7	Phosphate	Mg/l	0,25	< 0,7
8	Sulfate	Mg/l	10	250
9	Oxidation	Mg/l	undetectable	2
10	Ammonia	Mg/l	undetectable	1,5
11	Nitrite	Mg/l	0,2	3
12	Nitrate	Mg/l	2,0	50
13	E.Coli	Units/l	undetectable	0
14	Total Fecal Coliform	Units/l	undetectable	50

Conclusion: The water sample is safe for drinking according to the Code 09/2005/QĐ-BYT of the Ministry of Health of Vietnam.

Water sample collected and tested by

Tran Kiem Huy

Deputy Director of
Clean Water & Sanitation Program



Hoang Thi Hang Tam